

Ref.No. KKG/KPM/PBSC/004

Date 07/02/2022

STATEMENT ACCOMPANYING FORM - A

1. Name of the Building "Vijay Vikas International School", Vijayamangalam.
Door Number of the Building ---
2. Location (Street Number, ward Number, Name of Place, i.e., Corporation/Municipality/Township/Contonment R.S.F.No:121/2-Part of the Kambiliyampatti village & Panchayat, Kambiliyampatti, Near Vijayamangalam Toll, Perundurai Taluk, Erode District.
3. Year of Construction 08 Years
4. Approximate cost of construction as per current rate Rs.4,50,00,000.00/- (Rupees Four Crore and Fifty Lakh only)
5. Purpose for which the building is being used or Proposed to be used RCC Class Room, Library, Toilet, Lab, Staff Room, Principal Room & Computer Lab
6. Purpose for which the building has either to been used RCC Class Room, Library, Toilet, Lab, Staff Room, Principal Room & Computer Lab
7. Details for construction of the building (Particulars of the foundation soil. Specification of the various parts under
 - i) Foundation : RCC Column Footing & R.R Masonry in CM
 - ii) Basement : RCC. Plinth Beam with Brick Work in CM
 - iii) Superstructure : RCC Column with Brick Work in Cement Mortar
 - iv) Floor and Roof : R.C.C. Flat roof with Vitrified tiles
8. Period for which license is required effect from 01/04/2022 to 31/03/2025
9. Carpet Area of the building 13728.00 sft
- 10.No. of persons to be accomodated (including all) 1372 Nos.

Date: 07/02/2022

Signature of the Engineer

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was granted for the use of the building or it portion of the building originally is changed or altered sub-sequently.

Date : 07/02/2022

M. FRANCIS, M.A., B.ED., M.PHIL.,
PRINCIPAL

VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638 056.

Signature of the owner of the building

MANAGER
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638 056.

FORM - B

(Form of certificate of Structural Soundness Under-section (4) of section 4 of the Tamilnadu Public Buildings (Licensing) Act, 1965 (Madras Act 13 of 1965), referred to in rule 4 of the Tamilnadu Public Buildings (Licensing) Rules, 1966)

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features : -

(1) Foundation :

- | | | |
|---|---|-------------|
| i. Depth below ground level | : | 2.44 M |
| ii. Nature of soil met with at foundation level | : | Hard Moorum |
| iii. Pressure at foundation | : | 40 T/Sqm |
| iv. Probable safe bearing capacity of the strata met with at foundation | : | 50 T/Sqm |

(2) Superstructure :


- | | | |
|--|---|--|
| i. Maximum stress in the most critical section of masonry and concrete | : | Concrete - 40 T/Sqm Masonry - 400 Kgs/Sqm |
| ii. Nature of masonry and concrete and safe premissible stress | : | Concrete - 50 T/Sqm Masonry - 450 Kgs/Sqm |

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (Latest version) and other relevant Indian standards code of Practice and I declare that the building is structurally sound to be used as public building for the purpose noted in the statement. A licence may granted for the period of 3 Years

effect from 01/04/2022 to 31/03/2025

Date 07/02/2022

[Handwritten Signature]
Signature of the Engineer
District Panel Engineer Class - 1A




ANNEXURE TO FORM -B
STATEMENT TO ACCOMPANY THE CERTIFICATE OF
STRUCTURAL SOUNDNESS


| | |
|---|---|
| Location of the Building D.No., St., and build.of the place | R.S.F.No:121/2-Part of the Kambiliyampatti village & Panchayat, Kambiliyampatti, Near Vijayamangalam Toll, Perundurai Taluk, Erode District. |
| Age of the building | 08 Years |
| Number of Storeys | Upto First Floor |
| Short description of structure- steel R.C.C. Framed of load bearing masonry | RCC Framed Structure |
| Purpose for which the building is Certified for use sound | RCC Class Room, Library, Toilet, Lab, Staff Room, Principal Room & Computer Lab |
| The period forwhich the building will be structurally sound with | effect from <u>01/04/2022</u> to <u>31/03/2025</u> |
| No. of persons to be accomadated(including all) | 1372 Nos |

**THIS CERTIFICATE WILL NOT HOLD GOOD IN TIMES OF NATURAL CALAMITIES
LIKE FIRE, FLOOD AND EARTH QUAKE ETC.**

- 1.This Stability Certificate contains 11 pages including Namakkal District Class - I Panel & Erode District Class-I A Panel engineer certificate copy, and 3 Nos of Blue Prints Which is Prepared by me, with Ref No: SBBP&E/KPM/STB - PLAN/011, Dated: 07/02/2022.
- 2.Any construction and alteration activities should not be carried out on the working hours & days.
- 3.Periodical Maintanance should be carried out regularly.
- 4.Permanent Structures (having roof) are only covered in this stability certificate.
5. Grouting should be done in G.F & F.F Toilet walls, to arrest the masonry & R.C.C Beam Joints.
- 6.Weathering Coarse on the Second Floor (Every Where Water Stagnation are found, that water seeping in RCC Roof) that has to be rectified.
- 7.Expansion joint on Both side are to be well treated (Maintained) with out water seepage. First Floor Latrines tiles joint and wash basin, bottom are to be sealed with water proof materials, because of that Ground floor RCC roof and beam at staircase are getting damaged.
- 8.The above 3 Points (5, 6, 7) all to be carried out with in 3 month time are otherwise this certificate will not hold good.

Date : 07/02/2022


M. FRANCIS, M.A.B.ED.M.PHIL.,
PRINCIPAL
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638 056.


Er.K.KUMARAGURUPARAN
District Panel Engineer Class - 1A
MANAGER
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638 056.

FORM - C

(Form of certificate of Structural Soundness Under-section (4) of section 4 of the Madras Public Buildings (Licensing) Act, 1965 (Madras Act 13 of 1965), referred to in rule 4 of the Madras Public Buildings (Licensing) Rules, 1966)

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features :-

(1) Foundation :

- | | | |
|---|---|-------------|
| i. Depth below ground level | : | 2.44 M |
| ii. Nature of soil met with at foundation level | : | Hard Moorum |
| iii. Pressure at foundation | : | 40 T/Sqm |
| iv. Probable safe bearing capacity of the strata met with at foundation | : | 50 T/Sqm |


(2) Superstructure

- | | | |
|--|---|--|
| i. Maximum stress in the most critical section of masonry and concrete | : | Concrete - 40 T/Sqm Masonry - 400 Kgs/Sqm |
| ii. Nature of masonry and concrete and safe permissible stress | : | Concrete - 50 T/Sqm Masonry - 450 Kgs/Sqm |

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (Latest version) and other relevant indian standards code of Practice and I declare that the building is structurally sound to be used as public building for the purpose noted in the statement. A licence may granted for the period o 3 Years effect from 01/04/2022 to 31/03/2025

Date : 07/02/2022

K.K. Kumaraguruparan
7/2/22
Signature of the Engineer
District Panel Engineer Class - 1A



DECLARATION

I, K.KUMARAGURUPARAN, son of Sri.K.K.A.Kandasamy, 32, Sivagnanam Street, Opp. to Kamatchi Kalyana Mandapam, Bhavani - 638 301, do hereby declare that I possess the qualification experience specified in the fable to rule II of the Tamilnadu public buildings (Licensing) Rules, 1966 for issuing the certificate of structural soundness of the building covered by the certificate. Also under the G.O. MS No. 97 Municipal Administration and Water Supply (M.A.4) Department Dated 16.07.2001

- 1) This Report does not include any eventualities caused due to natural calamities
- 2) we hereby advice that periodical repairs and renovations shall be carried out to the entire building blocks regularly by every year and intimating me through writing
- 3) Further necessary fire fighting equipments should be kept in the premises and should be trained for for operation. If any fire accident/mishap occurs we are not held responsible.
- 4) Emergency exit to be provided as per norms
- 5) All electrical points, wiring/Gadgets has to checked properly and to be maintained periodically. For this, competent engineer is not held responsible for electrical defaults.
- 6) If any violation is found at a later stage after issue of this report, we are not held responsible and this report gets cancelled.
- 7) Further, this report covers the certification for the particular blocks, Floors only mentioned in the Plan - Legal aspects are not considered.

DISTRICT PANEL ENGINEER FOR :

Erode District Panel Engineer Class I-A
(R.Dis.No:25659/2007 C2)


Namakkal District Panel Engineer Class I
(R.Dis : 6073/99)

Station : KOMARAPALAYAM

Date : 07/02/2022

SIGNATURE OF THE CERTIFYING ENGINEER




M. FRANCIS, M.A., B.ED., M.PHIL.,
PRINCIPAL
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638 056.


MANAGER
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638 056.

PROCEEDINGS OF THE DISTRICT COLLECTOR, ERODE
PRESENT: THIRU T.UDHAYACHANDRAN, I.A.S.,


23/6/07

R.Dis. No. 25659/2007 C2

Dated: 21.6.2007

Sub: Tamil Nadu Public Buildings Licensing Act 1966 -
Panel of Private Practicing Engineers - Inclusion of the
name of Thiru K.Kumaraguruparan - In the Panel of
Private Practicing Engineer under Class I-A (One-A) -
Category in Erode District - Orders issued.

- Ref: 1. Engineer-In-Chief, WRO & Chief Engineer
(General) P.W.D, Chennai Letter No.
AEE/T1/JE/38051/06 dated: 31.5.2007.
2. Board of Engineers Proceedings No. BOE-18
Dated: 30.5.2007.



ORDER:

Under the provisions of Rule 11 of the Tamil Nadu Public Buildings Licensing Rules 1966, the name of Thiru K.Kumaraguruparan, residing at 'K.K.A.K.Illam', 32 Sivagnanam Street, Opp. To Kamatchi Amman Kalyana Mandapam, Bhavani 638 301, Erode District is hereby included in the Panel of Registered Engineers under Class I-A (One-A) Category in Erode District for the purpose of issuing Structural Soundness Certificate of Public Buildings (Buildings cost which exceeds Rs.30 Lakhs (Rupees Thirty Lakhs and above) with reference to the Tamil Nadu Public Building Licensing Act 1965 and the Rules covered there under.

(Sd.)T.Udhayachandran.
District Collector,
Erode.

/True Copy/By Order/

22-6-07
For Collector.

To

Er. K.Kumaraguruparan,
K.K.A.K.Illam,
32 Sivagnanam Street,
Bhavani 638 301.

Copy to: Superintending Engineer (PWD) Building Division, Erode.

Copy to: Engineer-In-Chief WRO and Chief Engineer (General) PWD,
Chepauk, Chennai 600 005.

Copy to: The Sub Collector, Gobichettipalayam.

Copy to: Tahsildar, Bhavani.

Copy to: Stock File of C2/L5

PROCEEDINGS OF THE DISTRICT COLLECTOR, NAMAKKAL.

PRESENT: THIRU. DAYANAND KATARIA, I.A.S.,

R.Dis.6073/99 (C2)

Dated: 11.11.99.

Sub: Tamil Nadu Public Buildings (Licensing) Act, 1965 -
Namakkal District - Drawing of Panel of
Registered Engineers under rule - Inclusion of
the name of Thiru K. Kumarakurubaran in the Panel
of Private Practising Engineers under Class I
Category in Namakkal District.

- Ref: 1. Application of Thiru K. Kumarakurubaran,
dated 5.2.99.
2. Chief Superintending Engineer (PWD) Buildings
(C&M) Salem, letter No. 554 M/F73/99 VA 6,
dated 21.7.99.
3. Engineer in Chief W.R.O. & Chief Engineer (General
P.W.D. letter No. AEE/T1/JE/36464/97, dt. 30.8.99.
4. Board of Engineer's proceedings 371/18-98,
dated 24.2.98.


In accordance with the instructions of the Engineer in
Chief, W.R.O & Chief Engineer (General), Public Works Department
Chennai in the reference 3rd and 4th cited, the name of
Thiru K. Kumarakurubaran, B.E., M.I.E., F.I.V., M.I.C.A.,
F.I.C.I., 10, J.K.K. Road, Near Head Post Office, B. Kumara-
palayam, Tiruchengode Taluk, Namakkal District is included
in the panel of Private Practising Engineers under the
Category of Class-I in Namakkal District for the purpose of
issuing structural soundness certificate for Public Buildings
in Namakkal District under the purview of the Tamil Nadu Public
Buildings Licencing Act, 1965.


M. FRANCIS, M.A., B.ED., M.PHIL.,
PRINCIPAL

VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,

To Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638 056.

Thiru K. Kumarakurubaran, B.E.,
10, J.K.K. Road,
Near Head Post Office,
B. Komarapalayam - 638 183,
Tiruchengode Taluk.


District Collector,
Namakkal

MANAGER
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638 056.